

Addendum #1

Montezuma County Backup Generators and Transfer Switches

1. Items that were brought up during walkthrough.

Item	Description	
1.5	All Generators to be in outdoor cabinets.	
1.6	All Generators to include battery maintainers.	
1.7	All Generators to include block heaters.	
1.8	All Generators to be liquid cooled.	
1.9	All Automatic Transfer Switches to be outdoor rated.	
1.10	Montezuma County Fairgrounds will require two 240V 400A 3Ph automatic transfer switches due to two 400A 3Ph service panels feeding main building.	